IC ENGINE OPERATING LOG

Equip #	091031	**Maximum Permitted Annual Operating Hours**	200	**Maximum M&T Annual Hours**	50
Permit #	G4557	**Facility ID**	161266	**Maximum Monthly M&T Hours (if limited)**	1
Site Location Name	Keller Peak Radio Tower				

Date	Operator	Hr Meter Start	Hr Meter End	M&T Hours	E. P Hours	Reason for use
1.1.24	SBCo.	-	2486.1	-	-	Starting Hours
1.4.24	SBCo.	2486.1	2489.2	-	3.1	Power Outage
1.30.24	SBCo.	2489.2	2490.1	.9	-	Maintenance
2.7.24-2.9.24	SBCo.	2490.1	2506.6	-	16.5	Power Outage
5.13.24	SBCo.	2506.6	2507.3	.7	-	Maintenance
5.23.24-5.24.24	SBCo.	2507.3	2526.2	-	18.9	Power Outage
5.31.24-6.1.24	SBCo.	2526.2	2542.5	-	16.3	Power Outage
6.13.24	SBCo.	2542.5	2543.2	.7	-	Maintenance
6.17.24	SBCo.	2543.2	2548.3	-	5.1	Power Outage
6.30.24	SBCo.	2548.3	2549.1	-	.8	Power Outage
7.22.24-7.23.24	SBCo.	2549.1	2563.5	-	14.4	Power Outage
8.19.24	SBCo.	2563.5	2570.4	-	6.9	Power Outage
9.5.24	SBCo.	2570.4	2571.1	.7	-	Maintenance
-	SBCo.	-	-	3	82	Hours Before Fire
9.7.24-10.8.24	SBCo.	2571.1	3265.1	-	694	Power Outage

Total Annual Hours	861	**Annual M&T hrs.**	3	**Annual E.P hrs.**	858

M&T = Maintenance & Testing **E.P. = Generator operation to provide emergency power**

Technicians notify your Supervisor if the hours of operation are within 25 hours of the Maximum Annual Permitted Hours or Maximum Annual M&T hours. Failure to do this could result in fines and penalties from the AQMD if the hours are exceeded prior to having a Request for Variance filed.