

**California Independent System Operator Corporation**

**Fifth Replacement FERC Electric Tariff**

**(Open Access Transmission Tariff)**

**Effective as of August 1, 2024**

commence in July 2021 for failure to provide RA Substitute Capacity by monthly RA Substitute Capacity deadlines that occur after the Outage has begun. Any such period of the Maintenance Outage for which the Scheduling Coordinator does not provide RA Substitute Capacity will be treated as a Forced Outage for purposes of assessing RAIM under Section 40.9 but the resource may not provide RA Substitute Capacity per Section 40.9.3.6.2.

### **9.3.2 Requirement for Approval**

An Operator or Scheduling Coordinator shall not take: (i) facilities that comprise the CAISO Controlled Grid; or (ii) Generating Units of Participating Generators out of service for the purposes of planned maintenance or for new construction or other work except as approved by the CAISO, except that final approval may not be required for a Transmission Maintenance Outage as provided in Section 9.3.9.1. The information relating to each Maintenance Outage submitted by a Participating Generator in accordance with Section 9.3.5, or by a Participating TO in accordance with Section 9.3.5, constitutes a request for a long-range Maintenance Outage and is not considered an Approved Maintenance Outage until the CAISO has notified the Participating Generator of such approval pursuant to Section 9.3.6, or the Participating TO pursuant to Section 9.3.6.

### **9.3.3 Request Submission and Information**

The Operator or Scheduling Coordinator of facilities that comprise the CAISO Controlled Grid or of a Participating Generator, Participating Intermittent Resource, Generating Unit, System Unit, Physical Scheduling Plant, Proxy Demand Resource, Reliability Demand Response Resource, Non-Generation Resource, Participating Load, or other resource subject to the outage management requirements of Section 9, shall use the ISO's outage management system to –

- (1) Submit all outage requests under Section 9.
- (2) Provide the required information about the outage and work to be performed using the nature of work categories described in the Business Practice Manual.
- (3) For transmission outage requests, additionally provide structured and detailed outage modeling information at the facility level and/or the breaker/switch level. If the work to be performed will require a switch position to change during the outage period, the Operator or Scheduling Coordinator must submit a separate outage request for each configuration.