

ELSINORE G7612

Date	Time	Week day	Time Ran	Run Time	Gen Hrs.	State	Type	Alarm Name	Notes
1/2/2024	8:07:28 AM	Tuesday			0.00	903.0 On	MJ	Generator Run	Remote Weekly Test
1/2/2024	8:22:34 AM	Tuesday	0:15:06		0.25	903.3 Off	MJ	Generator Run	Remote Weekly Test
1/9/2024	8:06:47 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
1/9/2024	8:21:54 AM	Tuesday	0:15:07		0.25	903.5 Off	MJ	Generator Run	Remote Weekly Test
1/16/2024	8:07:07 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
1/16/2024	8:22:14 AM	Tuesday	0:15:07		0.25	903.8 Off	MJ	Generator Run	Remote Weekly Test
1/23/2024	8:07:28 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
1/23/2024	8:22:31 AM	Tuesday	0:15:03		0.25	904.0 Off	MJ	Generator Run	Remote Weekly Test
1/30/2024	8:07:47 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
1/30/2024	8:22:49 AM	Tuesday	0:15:02		0.25	904.3 Off	MJ	Generator Run	Remote Weekly Test
2/5/2024	4:36:46 PM	Monday			0.00	On	MJ	Generator Run	Remote Weekly Test
2/5/2024	5:17:27 PM	Monday	0:40:41		0.68	904.9 Off	MJ	Generator Run	Remote Weekly Test
2/6/2024	8:07:05 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
2/6/2024	8:22:07 AM	Tuesday	0:15:02		0.25	905.2 Off	MJ	Generator Run	Remote Weekly Test
2/8/2024	8:37:53 AM	Thursday			0.00	On	MJ	Generator Run	Energy Systems PM
2/8/2024	9:18:42 AM	Thursday	0:40:49		0.68	905.9 Off	MJ	Generator Run	Energy Systems PM
2/13/2024	8:07:39 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
2/13/2024	8:22:25 AM	Tuesday	0:14:46		0.25	906.1 Off	MJ	Generator Run	Remote Weekly Test
2/20/2024	8:07:38 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
2/20/2024	8:22:40 AM	Tuesday	0:15:02		0.25	906.4 Off	MJ	Generator Run	Remote Weekly Test
2/20/2024	8:07:38 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
2/20/2024	8:22:40 AM	Tuesday	0:15:02		0.25	906.6 Off	MJ	Generator Run	Remote Weekly Test
2/23/2024	1:40:10 PM	Friday			0.00	On	MJ	Generator Run	Remote Weekly Test
2/26/2024	2:04:16 PM	Monday	0:24:06		0.40	907.0 Off	MJ	Generator Run	Remote Weekly Test
2/29/2024	8:02:59 PM	Thursday			0.00	On	MJ	Generator Run	Remote Weekly Test
2/29/2024	11:37:22 PM	Thursday	3:34:23		3.57	910.6 Off	MJ	Generator Run	Remote Weekly Test
3/1/2024	9:01:47 AM	Friday			0.00	On	MJ	Generator Run	SCE Outage 3/1/24
3/1/2024	8:07:59 PM	Friday	11:06:12		11.10	921.7 Off	MJ	Generator Run	SCE Outage 3/1/24
3/5/2024	8:07:14 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
3/5/2024	8:22:17 AM	Tuesday	0:15:03		0.25	921.9 Off	MJ	Generator Run	Remote Weekly Test
3/12/2024	9:07:29 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
3/12/2024	9:22:36 AM	Tuesday	0:15:07		0.25	922.2 Off	MJ	Generator Run	Remote Weekly Test
3/19/2024	9:06:47 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
3/19/2024	9:21:53 AM	Tuesday	0:15:06		0.25	922.4 Off	MJ	Generator Run	Remote Weekly Test
3/26/2024	9:07:06 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
3/26/2024	9:22:12 AM	Tuesday	0:15:06		0.25	922.7 Off	MJ	Generator Run	Remote Weekly Test
4/2/2024	9:07:24 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
4/2/2024	9:22:27 AM	Tuesday	0:15:03		0.25	922.9 Off	MJ	Generator Run	Remote Weekly Test

ELSINORE G7612

Date	Time	Week day	Time Ran	Run Time	Gen Hrs.	State	Type	Alarm Name	Notes
4/8/2024	8:20:28 AM	Monday			0.00	On	MJ	Generator Run	SCE Outage 4/8/24
4/8/2024	3:56:42 PM	Monday	7:36:14		7.60	930.6 Off	MJ	Generator Run	SCE Outage 4/8/24
4/9/2024	9:06:42 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
4/9/2024	9:21:45 AM	Tuesday	0:15:03		0.25	930.8 Off	MJ	Generator Run	Remote Weekly Test
4/11/2024	10:13:12 AM	Thursday			0.00	On	MJ	Generator Run	Remote Weekly Test
4/11/2024	10:28:19 AM	Thursday	0:15:07		0.25	931.1 Off	MJ	Generator Run	Remote Weekly Test
4/16/2024	9:06:58 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
4/16/2024	9:22:04 AM	Tuesday	0:15:06		0.25	931.3 Off	MJ	Generator Run	Remote Weekly Test
4/23/2024	9:07:17 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
4/23/2024	9:22:24 AM	Tuesday	0:15:07		0.25	931.6 Off	MJ	Generator Run	Remote Weekly Test
4/30/2024	9:06:36 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
4/30/2024	9:21:43 AM	Tuesday	0:15:07		0.25	931.8 Off	MJ	Generator Run	Remote Weekly Test
4/30/2024	9:06:36 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
4/30/2024	9:21:43 AM	Tuesday	0:15:07		0.25	932.1 Off	MJ	Generator Run	Remote Weekly Test
5/7/2024	9:06:55 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
5/7/2024	9:21:58 AM	Tuesday	0:15:03		0.25	932.3 Off	MJ	Generator Run	Remote Weekly Test
5/14/2024	9:07:15 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
5/14/2024	9:22:18 AM	Tuesday	0:15:03		0.25	932.6 Off	MJ	Generator Run	Remote Weekly Test
5/21/2024	9:07:31 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
5/21/2024	9:22:37 AM	Tuesday	0:15:06		0.25	932.8 Off	MJ	Generator Run	Remote Weekly Test
5/28/2024	9:06:50 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
5/28/2024	9:21:56 AM	Tuesday	0:15:06		0.25	933.1 Off	MJ	Generator Run	Remote Weekly Test
6/4/2024	9:07:10 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
6/4/2024	9:22:17 AM	Tuesday	0:15:07		0.25	933.3 Off	MJ	Generator Run	Remote Weekly Test
6/11/2024	9:07:30 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
6/11/2024	9:22:33 AM	Tuesday	0:15:03		0.25	933.6 Off	MJ	Generator Run	Remote Weekly Test
6/11/2024	12:22:12 PM	Tuesday			0.00	On	MJ	Generator Run	Energy Systems PM
6/11/2024	12:49:19 PM	Tuesday	0:27:07		0.45	934.0 Off	MJ	Generator Run	Energy Systems PM
6/18/2024	9:06:59 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
6/18/2024	9:22:06 AM	Tuesday	0:15:07		0.25	934.3 Off	MJ	Generator Run	Remote Weekly Test
6/25/2024	9:07:20 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
6/25/2024	9:22:27 AM	Tuesday	0:15:07		0.25	934.5 Off	MJ	Generator Run	Remote Weekly Test
7/2/2024	9:07:41 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
7/2/2024	9:22:44 AM	Tuesday	0:15:03		0.25	934.8 Off	MJ	Generator Run	Remote Weekly Test
7/6/2024	6:20:34 PM	Saturday			0.00	On	MJ	Generator Run	SCE Outage 7/6/24
7/6/2024	8:04:55 PM	Saturday	1:44:21		1.74	936.5 Off	MJ	Generator Run	SCE Outage 7/6/24
7/9/2024	9:07:02 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
7/9/2024	9:22:04 AM	Tuesday	0:15:02		0.25	936.8 Off	MJ	Generator Run	Remote Weekly Test

ELSINORE G7612

Date	Time	Week day	Time Ran	Run Time	Gen Hrs.	State	Type	Alarm Name	Notes
7/16/2024	9:07:19 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
7/16/2024	9:22:26 AM	Tuesday	0:15:07		0.25	937.0 Off	MJ	Generator Run	Remote Weekly Test
7/18/2024	7:13:58 PM	Thursday			0.00	On	MJ	Generator Run	SCE Outage 7/18-19/24
7/18/2024	11:59:59 PM	Thursday	4:46:01		4.77	941.8 Off	MJ	Generator Run	SCE Outage 7/18-19/24
7/19/2024	12:00:00 AM	Friday			0.00	On	MJ	Generator Run	SCE Outage 7/18-19/24
7/19/2024	6:58:50 AM	Friday	6:58:50		6.98	948.8 Off	MJ	Generator Run	SCE Outage 7/18-19/24
7/23/2024	9:07:40 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
7/23/2024	9:22:47 AM	Tuesday	0:15:07		0.25	949.0 Off	MJ	Generator Run	Remote Weekly Test
7/30/2024	9:08:02 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
7/30/2024	9:23:04 AM	Tuesday	0:15:02		0.25	949.3 Off	MJ	Generator Run	Remote Weekly Test
8/2/2024	8:02:41 AM	Friday			0.00	On	MJ	Generator Run	SCE Outage 8/2/24
8/2/2024	11:24:15 AM	Friday	3:21:34		3.36	952.6 Off	MJ	Generator Run	SCE Outage 8/2/24
8/6/2024	9:07:22 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
8/6/2024	9:22:25 AM	Tuesday	0:15:03		0.25	952.9 Off	MJ	Generator Run	Remote Weekly Test
8/13/2024	9:07:43 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
8/13/2024	9:22:46 AM	Tuesday	0:15:03		0.25	953.1 Off	MJ	Generator Run	Remote Weekly Test
8/20/2024	9:08:00 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
8/20/2024	9:23:07 AM	Tuesday	0:15:07		0.25	953.4 Off	MJ	Generator Run	Remote Weekly Test
8/27/2024	9:20:50 AM	Tuesday			0.00	On	MJ	Generator Run	Energy Systems PM
8/27/2024	9:47:12 AM	Tuesday	0:26:22		0.44	953.8 Off	MJ	Generator Run	Energy Systems PM
9/3/2024	9:07:42 AM	Tuesday			0.00	953.8 On	MJ	Generator Run	Remote Weekly Test
9/3/2024	9:22:48 AM	Tuesday	0:15:06		0.25	954.1 Off	MJ	Generator Run	Remote Weekly Test
9/10/2024	4:00:00 PM	Tuesday			0.00	On	MJ	Generator Run	SCE Outage 9/10-30/24
9/15/2024	4:00:00 PM	Sunday	120:00:00		120.00	1074.1 Off	MJ	Generator Run	SCE Outage 9/10-30/24
9/15/2024	4:00:00 PM	Sunday			0.00	On	MJ	Generator Run	SCE Outage 9/10-30/24
9/15/2024	8:00:00 PM	Sunday	4:00:00		4.00	1078.1 Off	MJ	Generator Run	SCE Outage 9/10-30/24
9/15/2024	11:00:00 PM	Sunday			0.00	On	MJ	Generator Run	SCE Outage 9/10-30/24
9/22/2024	11:00:00 PM	Sunday	168:00:00		168.00	1246.1 Off	MJ	Generator Run	SCE Outage 9/10-30/24
9/22/2024	11:00:00 PM	Sunday			0.00	On	MJ	Generator Run	SCE Outage 9/10-30/24
9/23/2024	12:00:00 PM	Monday	13:00:00		13.00	1259.1 Off	MJ	Generator Run	SCE Outage 9/10-30/24
9/23/2024	4:00:00 PM	Monday			0.00	On	MJ	Generator Run	SCE Outage 9/10-30/24
9/25/2024	8:00:00 AM	Wednesday	40:00:00		40.00	1299.1 Off	MJ	Generator Run	SCE Outage 9/10-30/24
9/25/2024	12:00:00 PM	Wednesday			0.00	On	MJ	Generator Run	SCE Outage 9/10-30/24
9/26/2024	10:00:00 AM	Thursday	22:00:00		22.00	1321.1 Off	MJ	Generator Run	SCE Outage 9/10-30/24
9/26/2024	10:10:00 AM	Thursday			0.00	On	MJ	Generator Run	SCE Outage 9/10-30/24
9/30/2024	2:00:00 PM	Monday	99:00:00		99.00	1420.1 On	MJ	Generator Run	SCE Outage 9/10-30/24
10/1/2024	9:08:04 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
10/1/2024	9:23:10 AM	Tuesday	0:15:06		0.25	1420.3 Off	MJ	Generator Run	Remote Weekly Test

ELSINORE G7612

Date	Time	Week day	Time Ran	Run Time	Gen Hrs.	State	Type	Alarm Name	Notes
10/8/2024	9:08:26 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
10/8/2024	9:23:28 AM	Tuesday	0:15:02		0.25	1420.6 Off	MJ	Generator Run	Remote Weekly Test
10/8/2024	10:41:59 AM	Tuesday			0.00	On	MJ	Generator Run	Energy Systems Repair/Maintenance
10/8/2024	10:52:39 AM	Tuesday	0:10:40		0.18	1420.8 Off	MJ	Generator Run	Energy Systems Repair/Maintenance
10/8/2024	10:54:28 AM	Tuesday			0.00	On	MJ	Generator Run	Energy Systems Repair/Maintenance
10/8/2024	11:20:59 AM	Tuesday	0:26:31		0.44	1421.2 Off	MJ	Generator Run	Energy Systems Repair/Maintenance
10/29/2024	9:07:40 AM	Tuesday			0.00	On	MJ	Generator Run	Remote Weekly Test
10/29/2024	9:12:45 AM	Tuesday	0:05:05		0.08	1421.3 Off	MJ	Generator Run	Remote Weekly Test

Elsinore G7612 FY 2024

Row Labels	Sum of Run Time
ENERGY SYSTEMS PM	1.6
ENERGY SYSTEM REPAIR	0.6
Remote Weekly Test	14.5
SCE OUTAGE 3/1/24	11.1
SCE OUTAGE 4/8/24	7.6
SCE OUTAGE 7/6/24	1.7
SCE OUTAGE 8/2/24	3.4
SCE OUTAGE 7/18-19/24	11.8
SCE OUTAGE 9/10-30/24	466
	518.3