

**BEFORE THE HEARING BOARD OF THE
SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT**

| | | |
|--------------------------|---|----------------------------|
| In the Matter of |) | Case No. 6139-8 |
| |) | Facility ID 152161 |
| VERIZON WIRELESS, |) | |
| |) | DECLARATION OF ZACH |
| Petitioner. |) | FEINGOLD |
| |) | |
| |) | |
| |) | |
| |) | |
| _____ |) | |

I, ZACH FEINGOLD, state:

1. I am a Verizon Wireless Regional Environmental Manager at Chino Hills, California.
2. This declaration is submitted pursuant to South Coast Air Quality Management District (“District”) Hearing Board Rule 4.
3. Verizon Wireless provides cellular communications services to its customers. Pursuant thereto, Verizon Wireless operates and maintains an extensive network of wireless facilities across the United States of America, including the facility located at 3000 Keller Peak Road, Big Bear City, California 92314, Facility ID 152161 (the “facility”).
4. Primary power to the facility is provided by Southern California Edison. In case of emergency, the facility must run on backup power, which includes the use of an internal combustion engine (“ICE”) operated pursuant to Permit to Operate No. F94141.

5. Condition No. 7 of Permit to Operate No. F94141 limits operations of emergency generator to 200 hours annually during the permit year, which includes no more than 50 hours in any one year for maintenance and testing purposes.

6. There is regular maintenance and testing performed on the emergency backup generator. Periodic inspections are performed by technicians assigned to the facility.

7. Non-compliance is beyond the reasonable control of Petitioner because the Line Fire, which started on 9/5/2024, caused a commercial power failure to the area. Governor Newsom declared a State of Emergency for the Line Fire on 9/7/2024. The facility's emergency generator began operating nonstop since the outage and has exceeded the 200 hours annual operating limit due to the ongoing commercial power failure in the area. As of October 9, 2024, the emergency generator has run 796 hours for the year.

8. Hourly rates for NO_x, CO, and VOC are 0.25 lb, 0.33 lb, and 0.25 lb, respectively. Excess emissions are estimated to be up to 1,500 hours over the 200 hours permit limit, which equates to 375 lb of NO_x, 495 lb of CO and 375 lb of VOC.

9. Operation under the order is not expected to result in a violation of Health and Safety (H&S) Code Section 41700 (nuisance).

10. I declare under penalty of perjury under the laws of the State of California that the foregoing is true and correct.

BY: *Zach Feingold*

Zach Feingold, Regional Environmental Manager

DATED: 10/10/2024