



# South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178  
(909) 396-2000 • [www.aqmd.gov](http://www.aqmd.gov)

SENT VIA E-MAIL AND USPS:  
[darlene.navarrete@lacity.org](mailto:darlene.navarrete@lacity.org)

December 4, 2014

Mr. Kellen Hoime, City Planning Assitant  
City of Los Angeles, City Hall  
Department of City Planning  
200 N. Spring Street, Room 750  
Los Angeles, CA 90012

**Draft Mitigated Negative Declaration (Draft MND) for the Proposed Installation, Use and Maintenance of a Wireless Telecommunications Facility Project at 1616 E. 24<sup>th</sup> St.; Southeast Area (NG-14-417-PL; ENV-2014-2749)**

The South Coast Air Quality Management District (SCAQMD) staff appreciates the opportunity to comment on the above-mentioned document both as a commenting agency and a responsible agency. The following comments are meant as guidance for the Lead Agency and should be incorporated into the Final Mitigated Negative Declaration.

In the project description, the Lead Agency proposes to install, operate and maintain a new unmanned wireless telecommunications facility comprised of 12 panel antenna, 12 remote radio units, two Raycaps, one microwave antenna, with supportive equipment on a new 50-foot monopine and a standby generator. If the proposed project includes a diesel-fueled generator which is rated greater than 50 brake horsepower (bhp), a permit would be required in accordance with SCAQMD rules including Rule 1470 – Requirements for Stationary Diesel-Fueled Internal Combustion and Other Compression Initial Engines and Rule 1110.2 – Emissions From Gaseous- and Liquid-Fueled Engines. If there are permit questions concerning the generator, they can be directed to Engineering and Compliance Staff at (909) 396-2315.

Please provide the SCAQMD with written responses to all comments contained herein prior to the adoption of the Final MND. The SCAQMD staff is available to work with the Lead Agency to address these issues and any other air quality questions that may arise. If you have any questions regarding this letter, please contact me at [jbaker@aqmd.gov](mailto:jbaker@aqmd.gov) or call me at (909) 396-3176.

Sincerely,

*Jillian Baker*

Jillian Baker, Ph.D.  
Program Supervisor  
Planning, Rule Development & Area Sources

LAC141120-12  
Control Number