



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178

(909) 396-2000 • www.aqmd.gov

SENT VIA USPS AND E-MAIL:

June 8, 2016

Lilian.Rubio@lacity.org

Darlene.Navarrete@lacity.org

Lilian Rubio, Planning Assistant
Los Angeles City Hall
Department of City Planning
200 N. Spring Street, 7th Floor
Los Angeles, CA 90012

Draft Mitigated Negative Declaration (Draft MND) for the Proposed Installation, Operation and Maintenance of a New Rooftop Telecom Facility at 1450 S. Rio Vista Avenue in Boyle Heights ENV-2015-1770-MND

The South Coast Air Quality Management District (SCAQMD) staff appreciates the opportunity to comment on the above-mentioned document both as a commenting agency and a responsible agency. The following comments are meant as guidance for the Lead Agency and should be incorporated into the Final Mitigated Negative Declaration.

In the project description, the lead agency proposes the installation, operation and maintenance of a wireless rooftop telecommunications facility. If the proposed facility will include a diesel-fueled generator that is rated greater than 50 brake horsepower (bhp), a permit would be required in accordance with SCAQMD rules including Rule 1470 – Requirements for Stationary Diesel-Fueled Internal Combustion and Other Compression Initial Engines. Permit questions can be directed to Engineering and Compliance Staff at (909) 396-2676.

Please provide the SCAQMD with written responses to all comments contained herein prior to the adoption of the Final MND. The SCAQMD staff is available to work with the Lead Agency to address these issues and any other air quality questions that may arise. Please contact Gordon Mize, Air Quality Specialist – CEQA Section, at (909) 396-3302, if you have any questions regarding these comments.

Sincerely,

Jillian Wong

Jillian Wong, Ph.D.
Program Supervisor
Planning, Rule Development & Area Sources

JW:MH:GM

LAC160602-04
Control Number