



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178

(909) 396-2000 • www.aqmd.gov

SENT VIA USPS AND E-MAIL:

May 4, 2016

kwarsinski@ci.beaumont.ca.us

Kyle Warsinski, Associate Planner
Community Development Department
City of Beaumont
550 E. 6th Street
Beaumont, CA 92223

Initial Consultation Letter for the for the Proposed Installation, Operation and Maintenance of a Temporary Relocation of a Rooftop Wireless Telecom Facility at 1447 Cherry Avenue (Case No. 16-CUP-03)

The South Coast Air Quality Management District (SCAQMD) staff appreciates the opportunity to comment on the above-mentioned document both as a commenting agency and a responsible agency. The following comments are meant as guidance for the lead agency for SCAQMD permitting purposes and should be incorporated into any applicable Draft CEQA document.

In the project description, the lead agency proposes the temporary relocation including the installation, operation and maintenance of a wireless rooftop telecommunications facility. If the proposed facility will include a diesel-fueled generator that is rated greater than 50 brake horsepower (bhp), a permit would be required in accordance with SCAQMD rules including Rule 1470 – Requirements for Stationary Diesel-Fueled Internal Combustion and Other Compression Initial Engines. Permit questions can be directed to Engineering and Compliance Staff at (909) 396-2315.

Please provide the SCAQMD with written responses to the comment contained herein prior to the adoption of a Final CEQA, applicable. The SCAQMD staff is available to work with the Lead Agency to address these issues and any other air quality questions that may arise. Please contact Gordon Mize, Air Quality Specialist – CEQA Section, at (909) 396-3302, if you have any questions regarding these comment.

Sincerely,

Jillian Wong

Jillian Wong, Ph.D.
Program Supervisor
Planning, Rule Development & Area Sources

JW:GM

RVC160429-07
Control Number