



Proposed Rule 1109.1 – NO_x Emission Reduction for Refinery Equipment and Related Operations

Working Group Meeting #22

June 30, 2021

Join Zoom Webinar

<https://scaqmd.zoom.us/j/92213416923>

Webinar ID: 922 1341 6923

Teleconference Dial-In: +1 669 900 6833

Agenda

2

- Progress and Status Since Working Group Meeting #21
- WSPA Proposal and Staff Response
- Updated Costs and Analysis
- BARCT Reassessment for Boilers and Heaters ≥ 40 MMBtu/hr
- BARCT Reassessment for FCCU
- Initial Concepts for Mass Emissions Approach
- Next Steps

Progress and Status Since WGM #21

3

Status and Progress Since Last WGM

4

- Norton's final review of the facility-provided cost has been posted
- Completed BARCT reassessment, including cost-effectiveness, incremental cost-effectiveness, and near limit assessment for units with high cost-effectiveness,
 - Large boilers and heaters
 - FCCUs
- Continued meetings with stakeholders, WSPA, CCEEB, and environmental representatives
- Meeting with Ramboll to discuss WSPA's cost estimates
- Public hearing moved from September to November 2021

Comment Letters from Environmental and Community Groups

5

- Received two comment letters from seven environmental and community groups
- First letter received on May 20, 2021, requested that any proposal to create a facility-wide mass caps be rejected
 - PR 1109.1 should transition refineries to a command-and-control regulatory framework with equipment-specific limits
 - Facility-wide mass cap undermines the rule’s objectives by:
 - Recreating the NOx RECLAIM program at the facility level, which conflicts with CMB-05’s mandate to transition facilities to command-and-control
 - Allowing refineries to “trade” emission allowances between various sources to meet the “cap” and avoid installing lifesaving pollution controls on a range of equipment
 - A mass cap is difficult to enforce
 - Concerns regarding uncertainties associated with calculating facility-wide mass caps for each refinery, including equipment concentration and flow uncertainties, and emissions monitoring calibration and downtime issues



Received Two Comment Letters (*cont.*)

6

- Second comment letter submitted on June 17, 2021 to the South Coast AQMD Board:
 - Requested the South Coast AQMD transition refineries from RECLAIM to a command-and-control system
 - Concerned that Western States Petroleum Association (WSPA) has a proposal to continue RECLAIM
 - Demanded that refineries install pollution control technologies that have been available for decades
 - Requested the Board to direct staff to finalize Rule 1109.1 and bring it to the Board as soon as possible but no later than September 2021



Socioeconomic Assessment Update

7

- Staff is currently preparing Draft Socioeconomic Impact Assessment (SIA)
 - Including estimated public health benefits and projected emission reductions
- Separate third-party reviews will be conducted for:
 - Draft SIA (Kleinhenz Economics)
 - Public Health Benefits (Industrial Economics/IEc)
- To address Governing Board Member comments, staff will estimate pass-through of PR 1109.1 compliance costs onto gasoline prices
 - Cost pass-through is the increase in retail price arising due to an increase in operating costs
 - Staff working with third-party contractor
 - Dr. Erich Muehlegger, Associate Professor, UC Davis
 - Research focus in environmental and energy policy
 - Recent publication record on cost pass-through in the U.S. oil refinery sector

CEQA Assessment Update

8

- Staff is preparing a Draft Subsequent Environmental Assessment to the December 2015 Program Environmental Assessment for NOx RECLAIM and the March 2017 Program Environmental Impact Report for the 2016 AQMP
 - Will include PR 429.1, PAR 1304, rescind Rule 1109, and pending rule development
 - Will be released for a 45-day public review and comment period
- Staff has met with stakeholders who provided updated data which is being incorporated into the Draft Subsequent Environmental Assessment

WSPA Proposal and Staff's Response

9

WSPA Bridge Concept

- On June 2nd WSPA presented an option for a bridge that would generally retain the RECLAIM structure with the PR 1109.1 endpoints
- WSPA Concept Summary
 - Use Regulation XX as the “bridge” to deliver BARCT-equivalent NO_x emissions reductions
 - Complete remaining BARCT assessments
 - Adjusted BARCT-equivalent facility allocations are met through installation of control equipment at a facility level
 - Adjust (i.e., shave) facility allocations to start in 2023-2025 timeframe
 - Restrict new purchases of IYB NO_x RTCs starting 2023
 - Voluntary exit option to Regulation XX
 - At the end of the last compliance year fully sunset RECLAIM

Staff's Response to WSPA Proposal

11

RECLAIM is Not Needed for Bridge

- NOx emission limits that will not require reductions can be the bridge until units fully implement landing rules
- Concerned about unnecessarily prolonging RECLAIM
- Industry comments in the past have focused on disproportionate impacts

Amendments to Regulation XX are Challenging

- Establishing “shave” will be resource intensive
- Must determine the amount of RTCs that would be retired upon exiting RECLAIM
- Analysis of market impacts as facilities exit RECLAIM is needed

Equity to Non-Refinery Facilities

- Some non-refinery facilities have compliance dates after refineries
- Refineries had information to purchase infinite year block RTCs before non-refineries
- New facilities that did not receive an initial allocation

State and Federal Approvability

- Revisions need approval by CARB and U.S. EPA
- Concerns about use of RTCs in lieu of BARCT – Health and Safety Code Section 40920.6
- U.S. EPA is concerned about prolonging RECLAIM

Staff's Proposal for Bridge Limits

- Industry concerns for the bridge can be addressed without retaining RECLAIM
- Staff presented bridge concepts during Working Group Meeting #21
- Interim limits would reflect current operating conditions until BARCT emission limits are achieved and ensure enforceable emission limits are in place
- Staff included potential bridge limits for most categories in last working group meeting
- The proposed limits that are based on current NOx levels will be based on annual average CEMS data

Table from Working Group Meeting #21

Unit	NOx (ppmv)	CO (ppmv)	Percent O2	Averaging Time (Rolling Average)	Comment
Boilers and Heaters <40 MMBtu/hour	40	400	3	2 hour	Required permit limit
Boilers and Heaters ≥40 MMBtu/hour	Discussed on following slide				
FCCU	40	500	3	365 day	Consent decree or permit limits
Gas Turbines	20	130	15	24 hour	
Petroleum Coke Calciner	70	2,000	3	365 day	Current NOx levels
SRU/TG Incinerators	100	400	3	24 hour	
SMR Heaters	60 without SCR 20 with SCR	400	3	24 hour	
SMR Heaters with Gas Turbine	5	130	15	24 hour	May not need interim limits, permit limit required prior to existing RECLAIM
Sulfuric Acid Furnaces	30	400	3	365 day	
Vapor Incinerators	130 lb/MMscf	400	3	3	Default emission factor

Staff's Proposed Bridge Concept for Boilers and Heaters ≥ 40 MMBtu/hr

13

- Large boilers and heaters have wide variation and most units do not have existing permit limits
- Considering establishing a 0.03 lb/MMBtu facility-wide bridge limit for boilers and heaters ≥ 40 MMBtu/hr
 - Mirrors the requirement in the original Rule 1109
 - Consistent with BAAQMD's Regulation 9 which establishes 0.033 lb/MMBtu for boilers and heaters at petroleum refineries

Staff Recommendation:

Establish facility-wide interim limit for boilers and heater ≥ 40 MMBtu/hr at 0.03 lb/MMBtu

Facility-Revised Cost Data

14

Facility-Revised Cost Data

- Staff is reassessing the proposed NO_x BARCT limit for major categories based on the revised cost data provided by the facilities in March 2021
- Summary of facility-provided cost data
 - Received revised cost from facilities in March 2021
 - Received 108 new or revised SCR cost estimates
 - Previously received cost for 58 SCR projects
 - Majority of the facility-revised costs data was for boilers and heaters ≥ 40 MMBtu/hr retrofits but also received revised costs for NO_x controls or unit replacement for FCCUs, gas turbines, vapor incinerators, and flares
 - Received facility-revised cost estimates for SCR, SCR upgrades, wet gas scrubbers, burners, fuel gas treatment, dry low-NO_x combustor, and unit replacement
 - Costs ranged from \$2 MM to \$300 MM per project

Norton Engineering's Feedback on Facility-Revised Cost Data (*cont.*)

17



- Norton's cost assessment stated:

Facility-Revised Burner Costs

Most of the facility-revised cost data for burners was consistent with "typical" costs

15 of the estimates were within expected range and 5 were outliers

Facility-Revised SCR Costs

Norton's estimated SCR costs roughly passes through the middle of the refinery's initial cost data but is at the lower end of the facility-revised data

15 facility-revised datapoints were significantly higher

Increases to the cost estimates are not unusual as project scope definition improves during the later stages of engineering design

- Norton concluded the costs provided by the facilities are not unreasonable, considering potential complexity

South Coast AQMD-Revised Cost Curves


18

Boilers & Heaters ≥ 40 MMBtu/hour

Power Curve used by U.S. EPA SCR Cost Model

19


- Staff used facility-revised data to update the power curve used by U.S. EPA SCR Cost Model
 - Included all datapoints received for SCR installations on boilers and heaters ≥ 40 MMBtu/hr
- Graph shows power curve with facility-revised cost data
 - Revised curve used to update the U.S. EPA cost model




South Coast AQMD-Revised Cost Curve for Burners

20

- Facilities provided 20 revised total installed cost estimates for ULNB/LNB
 - Staff used all facility-revised cost data to update the cost curve used to estimate burner installation costs



Boilers & Heaters BARCT Reassessment



Boilers and Heaters ≥ 40 MMBtu/hr - Background

22

- For boilers and heaters ≥ 40 MMBtu/hr, staff originally proposed a BARCT limit of 2 ppm with ULNB/SCR in WGM #9 on December 12, 2019
 - Third-Party Engineering Consultants supported staff's conclusion
 - Presented conclusions in WGM #16 on December 10, 2020
- Industry stakeholders' comments:
 - Technical feasibility of achieving 2 ppm with ULNB and SCR
 - Costs used to estimate cost-effectiveness

Slide from Working Group Meeting #9

Initial BARCT NO_x Limits for Cost-Effectiveness Analysis for Heaters ≥ 40 MMBtu/hr Using Refinery Gas 47

2 ppm

Combination of SCR (95% reduction) and ULNB (< 30 ppm)

Potential NO_x BARCT Emission Limits

Emissions from this category are high:
Total NO_x emission for heaters ≥ 40 MMBtu/hr is 5.24 tpd

Boilers and Heaters ≥ 40 MMBtu/hr - Background (cont.)

23

Technology Feasibility to achieve 2 ppm with ULNB and SCR

- Working Group Meeting #17, two-stage SCR presented as alternative pathway to 2 ppm
 - Staff assumed 25% increase in cost
 - Stakeholders indicated costs could increase by over 80% of single-stage SCR installation
 - Space constraint issues and costs are significantly magnified


Costs used to estimate cost-effectiveness

- Facilities submitted revised cost data and staff reassessed proposed BARCT limits for major categories
- If cost data was not provided, staff used facilities suggested cost of 80% increase of single-stage reactor for two-stage SCR

Slide from Working Group Meeting #17


Options for Achieving Proposed NO_x Limit

7



Boilers and Heaters by Category

24



Boilers and Heaters ≥ 40 MMBtu/hr - Technical Assessment

25



- Technical assessment to achieve 5 ppm and 2 ppm NOx levels detailed in prior Working Group Meetings
- Technical assessment for 50 ppm level using Low-NOx Burner on following slide

Boilers and Heaters ≥ 40 MMBtu/hr - Technical Assessment for Burner Technology

26

- American Petroleum Institute (API) provides recommended guidelines for refinery fired heaters (API 560) and burners (API 535)
- Recommended guidelines include heat density and minimum burner spacing for optimal operation and safety
 - A higher heat density (MMBtu/hr/ft²) can result in higher flame temperatures and therefore increase NOx emissions
 - If burner spacing is not adequate, this can lead to flame interactions or coalescing which results in increased NOx emissions and potential impingement of the tubes
 - Not operating within guidelines is considered “suboptimal” which can impact burner NOx performance
- Norton’s Report concluded:
 - Under optimal conditions, 30 ppm NOx can be achieved with ULNB
 - Suboptimal burner installations will achieve 40 – 50 ppm
- Staff’s prior technology assessment concluded that ULNBs *can* achieve 30 ppm
 - Many units already achieving <30 ppm using ULNB technologies
- Staff received considerable feedback from stakeholders regarding the challenges of ULNB installation and has acknowledged not all units can be retrofitted with ULNB
- Technology assessment will consider 50 ppm NOx levels from burner technology

Boilers and Heaters ≥ 40 MMBtu/hr - Cost Estimates

27

50 ppm
NOx

Low NOx
Burners

Revised cost estimates ranged from \$3.4 MM to \$31 MM

5 ppm
NOx

Single Stage SCR

Revised cost estimates for boilers ranged from \$10 MM to \$40 MM

Revised cost estimates for heaters ranged from \$2 MM to \$45 MM

2 ppm
NOx

Two Stage SCR, ULNB Single Stage, Unit Replacement

Staff received cost estimates from facilities that included: unit replacement, combined SCR and low-NOx burners, and single SCR projects

When costs were not provided, staff estimated costs based on dual reactor SCR

Revised cost estimates for boilers ranged from \$2 MM to \$70 MM

Revised cost estimates for heaters ranged from \$5 MM to \$244 MM

BARCT Reassessment Heaters
 ≥ 40 MMBtu/hr



Heaters ≥ 40 MMBtu/hr - Initial BARCT NOx Limit


	RECLAIM 2005/2015 BARCT	Existing Units	Other Regulatory	Technology Assessment	Initial BARCT NOx Limits	Cost-Effectiveness and Incremental Cost- Effectiveness
40 to 110 MMBtu/hr	25/2 ppm	1.4 - 134 ppm	9 - 30 ppm	50, 5, & 2 ppm	50, 5, & 2 ppm	Need to assess cost- effectiveness and incremental cost- effectiveness
>110 MMBtu/hr	5/2 ppm	1.5 - 70 ppm	9 - 30 ppm	50, 5, & 2 ppm	50, 5, & 2 ppm	Need to assess cost- effectiveness and incremental cost- effectiveness

Emissions from this category are high:
Total NOx emission for heaters ≥ 40 MMBtu/hr is 5.24 tpd

Heaters ≥ 40 MMBtu/hr - Approach for Establishing Proposed BARCT Limit

30


- Based on revised cost estimates, the average cost-effectiveness to achieve either 5 ppm or 2 ppm are above \$50,000 per ton of NO_x for heaters ≥ 40 MMBtu/hr
- To reduce the average cost-effectiveness, staff is proposing that units operating between the proposed and near limit would not be required to meet the proposed NO_x limits
- Units that are at or below the “near limit” will not be required to meet proposed NO_x limit in Table 1 provided:
 - Operator accepts a permit limit at or below the near limit
- Near limit units are excluded from the cost-effectiveness calculation
 - Near limit units will not be required to meet the NO_x limits in Table 1
 - No additional retrofit costs associated with these units



Heaters ≥ 40 MMBtu/hr - Approach to Establishing Near Limits (*cont.*)

31

- An iterative process was used to identify the near limit NOx concentration level where the cost-effectiveness for units above the near limit would be less than \$50,000 per ton of NOx reduced
- For the proposed NOx limit of 2 ppm, no near limit was identified that will reduce the cost-effectiveness to below \$50,000 per ton of NOx reduced
- For the proposed NOx limit of 5 ppm, removing units at or below near limits will reduce the cost-effectiveness to below \$50,000 per ton of NOx reduced



Heaters ≥ 40 MMBtu/hr - Approach to Establishing Near Limits (*cont.*)

32

- Several units with combined stacks that have different sizes
- For near limits assessment, staff considered units with combined stacks to fall into the larger category
 - If multiple units are combined:
 - One unit is >110 MMBtu/hr and the other are less  >110 MMBtu/hr
 - All units are between $40 - 110$ MMBtu/hr  $40 - 110$ MMBtu/hr
 - One is >40 MMBtu/hr and the other units are less  $40 - 110$ MMBtu/hr

Heaters ≥ 40 MMBtu/hr – Low Use Unit

- In addition to the units performing near the NOx limits, there is one unit >110 MMBtu/hr that is operating at a low capacity (approximately 12 percent)
 - Unit has very high cost-effectiveness
~\$184,000 per ton reduced
 - Low emission reductions – 0.02 tpd
- Staff is proposing to include a low-use exemption for units operating less than 15 percent capacity
 - Low-use units will not have to meet the Table 1 NOx limits

Heaters 40 to 110 MMBtu/hr - Establishing a Near Limit to Reduce the Average Cost-Effectiveness

Heaters 40 – 110 MMBtu/hr

Potential Near Limit (ppm)*	Cost-Effectiveness of Remaining Units	Number Units Meeting Near Limit*	Foregone emissions (tpd)
No Near Limit	\$53,000	0/67 unit	Baseline
10	\$53,000	1/67 unit	0.001
15	\$51,000	8/67 units	0.02
18	\$48,000	12/67 units	0.05

* Based on annual average emissions

18

\$48,000

12/67 units

0.05

- Cost-effectiveness for the 12 units that are currently achieving NOx levels between 5 and 18 ppm is high
 - Cost-effectiveness ranges between \$200,000 to \$750,000 per ton of NOx reduced
 - Emission reductions are low compared to other units
- **Staff Recommendations:**
 - Include near limit of 18 ppm
 - Reassess the cost-effectiveness and incremental cost-effectiveness

Heaters 40 – 110 MMBtu/hr - Cost-Effectiveness and Incremental Cost-Effectiveness

Heaters 40 – 110 MMBtu/hr					
50 ppm		5 ppm*		2 ppm	
Cost Effectiveness	Emission Red (tpd)	Cost Effectiveness	Emission Red (tpd)	Cost Effectiveness	Emission Red (tpd)
\$40,000	0.33	\$48,000	1.63	\$94,000	1.99

* Excludes near limit units

50 → 5 ppm

5 → 2 ppm

Incremental Cost Effectiveness	\$50,000	\$293,000
Incremental Emission Reduction (tpd)	1.30	0.37

Heaters >110 MMBtu/hr - Establishing a Near Limit to Reduce the Average Cost-Effectiveness

36

- Some of the heaters >110 MMBtu/hr category have very high emission reduction potentials
- To minimize the amount of foregone emission reductions, staff considered two criteria for evaluating the near limit:
 1. Concentration limit
 2. Overall emission reduction potential for retrofit
- Staff used the iterative process for the different concentration limits but units that have the potential to achieve greater than 20 tons per year NO_x reductions were not removed
 - Evaluated a 10 ton per year limit as a secondary limit but cost-effectiveness remained greater than \$50,000
- Units that have the potential to achieve 20 tons per year or greater reductions will have to retrofit even if they are achieving less than the near limit

Heaters >110 MMBtu/hr - Establishing a Near Limit to Reduce the Average Cost-Effectiveness

Heaters >110 MMBtu/hr

Potential Near Limit (ppm)*	Cost-Effectiveness of Remaining Units	Number Units Meeting Near Limit**	Foregone emissions (tpd)
No Near Limit	\$56,000	0/51 unit	None
10	\$55,000	5/51 units	0.03
15	\$54,000	8/51 units	0.06
18	\$52,000	12/51 units	0.15
20	\$50,500	13/51 units	0.19
22	\$50,000	17/51 units	0.23

22	\$50,000	17/51 units	0.23
----	----------	-------------	------

- Cost-effectiveness for the 17 units that are currently achieving NOx levels between 5 and 22 ppm with less than 20 tpy potential reductions is high
 - Average cost-effectiveness for near limit units ~\$85,000 per ton
 - Average cost-effectiveness for near limit units with potential reductions greater than 20 tons/year is \$44,000 per ton
- **Staff Recommendations:**
 - Include near limit of 22 ppm provided potential emission reductions are not greater than 20 tpy
 - Reassess the cost-effectiveness and incremental cost-effectiveness

* Based on annual average emissions
 + Excludes low-use unit and units with the potential to reduce more than 20 tpy Nox based on 2017 baseline and Table 1 NOx limits

Heaters >110 MMBtu/hr - Cost-Effectiveness and Incremental Cost-Effectiveness

Heaters >110 MMBtu/hr					
50 ppm		5 ppm*		2 ppm	
Cost Effectiveness	Emission Red (tpd)	Cost Effectiveness	Emission Red (tpd)	Cost Effectiveness	Emission Red (tpd)
\$72,000	0.07	\$50,000	1.84	\$110,000	2.22

* Excludes near limit units and low-use unit

50 → 5 ppm

5 → 2 ppm

Incremental Cost Effectiveness	\$49,000	\$400,000
---------------------------------------	-----------------	------------------

Incremental Emission Reduction (tpd)	1.77	0.38
---	-------------	-------------

Heaters ≥ 40 MMBtu/hr - Staff Recommendation

39


50 ppm
NOx

Does not represent the Best Available Retrofit Technology

SCR achieves significantly greater emission reductions than LNB and is cost-effective


5 ppm
NOx

Challenging but technically feasible

Cost-effective provided near limits are allowed for units performing the BARCT limit

- Near limit units will have to accept a permit limit
- Rule will allow time for facilities to request permit change



2 ppm
NOx

Not cost-effective to achieve 2 ppm

Incremental cost-effectiveness is high – considerable cost for diminishing emission reduction

Heaters ≥ 40 MMBtu/hr - BARCT Assessment

40



(1) 400 ppm Carbon Monoxide, 3% Oxygen Correction, 24 hour rolling average

(2) Previously estimated emission reduction to 2 ppm without near limits: 4.21 tpd



Boilers (≥ 40 MMBtu/hr) Reassessment

Boilers ≥ 40 MMBtu/hr - Initial BARCT NOx Limit

	RECLAIM 2005/2015 BARCT	Existing Units	Other Regulatory	Technology Assessment	Initial BARCT NOx Limits	Cost-Effectiveness and Incremental Cost- Effectiveness
40 to 110 MMBtu/hr	2 ppm	70 - 105 ppm	5 - 9 ppm	50, 5, & 2 ppm	50, 5, & 2 ppm	Need to assess cost- effectiveness and incremental cost- effectiveness
>110 MMBtu/hr	2 ppm	4.2 - 117 ppm	5 - 9 ppm	50, 5, & 2 ppm	50, 5, & 2 ppm	Need to assess cost- effectiveness and incremental cost- effectiveness

Total NOx emission for boilers 40 – 110 MMBtu/hr is 0.052 tpd
 Total NOx emission for boilers >110 MMBtu/hr is 2.51 tpd

Boilers ≥ 40 MMBtu/hr – Cost Submission

43

Boilers 40 – 110 MMBtu/hr

- 3 boilers at one facility
 - 1 main boiler and 2 back-up
- Staff received capital cost from facility to achieve 5 ppm level of NOx
 - Used 4.5-time multiplier to account for installation costs (per Norton recommendation in the 2015 BARCT assessment)
 - Costs estimated ~ \$10.5 MM
- For 2 ppm cost estimate, staff increased cost by 80% to account for two-stage SCR

Boilers >110 MMBtu/hr

- 20 Boilers
- Staff received eight revised cost estimates from facilities to achieve 5 ppm
 - Based on revised costs, SCR costs increased from \$3 to \$14 MM
- Costs included SCR upgrades or installations and ranged from:
 - \$2.4 MM to \$39 MM for SCR retrofits
 - \$2 MM for SCR upgrades

Boilers 40 – 110 MMBtu/hr - Cost-Effectiveness and Incremental Cost-Effectiveness

Staff Comment:

No near limit provision needed

Boilers 40 – 110 MMBtu/hr					
50 ppm		5 ppm		2 ppm	
Cost Effectiveness	Emission Red (tpd)	Cost Effectiveness	Emission Red (tpd)	Cost Effectiveness	Emission Red (tpd)
\$13,000	0.024	\$25,000	0.049	\$46,000	0.051

50 → 5 ppm

5 → 2 ppm

Incremental Cost Effectiveness	\$37,000	\$656,000
Incremental Emission Reduction (tpd)	0.025	0.002

Boilers >110 MMBtu/hr - Cost-Effectiveness and Incremental Cost-Effectiveness

Staff Comment:

No near limit provision needed

Boilers > 110 MMBtu/hr					
50 ppm		5 ppm		2 ppm	
Cost Effectiveness	Emission Red (tpd)	Cost Effectiveness	Emission Red (tpd)	Cost Effectiveness	Emission Red (tpd)
\$12,000	0.72	\$12,000	2.21	\$19,000	2.38

50 → 5 ppm

5 → 2 ppm

Incremental Cost Effectiveness	\$12,000	\$102,000
Incremental Emission Reduction (tpd)	1.49	0.18

Boilers ≥ 40 MMBtu/hr – Staff Recommendation

46


50 ppm
NO_x

Does not represent the Best Available Retrofit Technology

SCR achieves significantly greater emission reductions than LNB and is cost-effective


5 ppm
NO_x

Challenging but technically feasible

Cost-effective


2 ppm
NO_x

Technical feasibility is uncertain

Cost-effective


Incremental cost-effectiveness is very high

No established threshold for I-CE

I-CE Assessment shows diminishing emission reductions for significant additional costs


Boilers ≥ 40 MMBtu/hr - Staff Recommendation

47



(1) 400 ppm Carbon Monoxide, 3% Oxygen Correction, 24 hour rolling average

(2) Previously estimated emission reduction to 2 ppm: 2.43 tpd




FCCU BARCT Reassessment

FCCU - BARCT Assessment Follow-Up

49

- BARCT assessment presented in Working Group Meeting #10 on February 18, 2020
 - Staff recommended 2 ppm limit
 - Cost-Effectiveness \$37,000 based on original cost estimates
- Stakeholders raised a concern over the technical feasibility and cost-effectiveness for units with existing SCRs to achieve 2 ppm



FCCU - Technical Assessment to Achieve 2 ppm

50

- Previously staff assumed FCCUs with existing SCRs would be upgraded to meet the proposed BARCT limit of 2 ppm
- Based on facility engineering assessments:
 - Not technologically feasible to upgrade all units with existing SCRs to achieve <5 ppm NOx
 - Major reconfiguration, re-engineering, and re-design of the existing unit
 - Demolition of existing SCR and structures
 - Major infrastructure modifications to the unit
 - Cost to replace SCR are substantially higher than upgrade
 - Some units will require replacement of the FCCU regenerator (combustor) to achieve 2 ppm
 - Substantial costs and technical feasibility to achieve 2 ppm is not certain
 - SCR upgrade on units with existing SCRs can achieve ~8 ppm NOx

FCCU - BARCT Reassessment

51

8 ppm
NOx

SCR upgrade

2 ppm
NOx

SCR

SCR and Regenerator Upgrade

LoTOx with Wet Gas Scrubber

5 FCCUs

- 2 units without NOx Controls
 - 1 unit is in process of installing a SCR designed for 2 ppm
- 3 units with NOx Controls
 - 1 unit performing well below 2 ppm (annual average)
 - 2 units with SCR that would need:
 - SCR replacement and new regenerator to achieve 2 ppm
 - Upgrades to existing SCR to achieve 8 ppm

FCCU BARCT Assessment

52

	RECLAIM 2015 BARCT	Existing Units	Other Regulatory	Technology Assessment	Initial BARCT NOx Limit	Cost-Effectiveness and Incremental Cost-Effectiveness
FCCU	2 ppm	1.2 – 36 ppm	40 – 125 ppm	8 - 2 ppm	8 - 2 ppm	Need to assess cost-effectiveness and incremental cost-effectiveness

Total NOx emission is 0.43 tpd

FCCU - Cost Estimates

- Staff received 2 facility-revised cost for FCCU retrofit
- Costs include SCR upgrades, SCR installation, regenerator (combustor) replacement, wet gas scrubber (multipollutant control)

8 ppm
NOx

Revised cost estimates
for SCR upgrade ranged
from \$1 MM to \$3 MM

2 ppm
NOx

Staff estimates for new SCR installation
ranges from \$75 MM to \$103 MM based of
original costs provided

Facility provided cost for combustor
replacement ~\$200 MM

Facility Provided Cost for LoTOx wet gas
scrubber ~\$220

FCCU - BARCT Reassessment

54

- Staff will reassess the cost-effectiveness for FCCUs to meet 2 ppm and 8 ppm
- One facility provided cost for a wet gas scrubber that can achieve multi-pollutant emission reductions
 - Wet gas scrubber can reduce NO_x, SO_x, and PM emissions
 - Cost considerably more than SCR
- Only NO_x reductions are required for PR 1109.1, so staff evaluated the cost-effectiveness of that unit based on:
 - LoTO_x with wet gas scrubber is multi-pollutant control achieving NO_x and SO_x reductions
 - SCR achieving NO_x reductions only
 - SCR capital cost estimated based on vendor quote for similar sized FCCU at another refinery
 - Increased cost by factor of 4.5 for installation costs
 - Increased cost by 20% to account for SB 54 which requires refineries to hire unionized labor
 - Included 2 times retrofit factor to address space constraints – maximum multiplier in U.S. EPA Cost Model

FCCU - Cost Effectiveness to Achieve 2 ppm with Wet Gas Scrubber or SCR

55

	Multi-Pollutant Scrubber	SCR
Estimated Present Worth Value	\$218 MM	\$ 76 MM
Emission Reductions (Lifetime tons)	NOx: 2,071 SOx: 2,027	NOx: 2,071
Cost Effectiveness	\$46,000	\$24,000

FCCU - Outliers Assessment

56

- Based on facility-revised cost data, 2 ppm is not cost-effective for class and category
 - 2 FCCUs have high cost-effectiveness to achieve 2 ppm
 - Units already equipped with NOx control
 - High cost to replace existing controls or modification to units to achieve 2 ppm
 - Cost outliers due to high cost and the low emission reductions to achieve 2 ppm
- Staff reassessed:
 - Cost-effectiveness and incremental cost-effectiveness of two cost outliers to retrofit to achieve 8 and 2 ppm
 - Cost-effectiveness of remaining two units to achieve 2 ppm with the outliers removed

FCCU - Cost-Effectiveness and Incremental Cost-Effectiveness with Existing SCR

- Based on revised cost estimates from facilities, units with SCR:
 - 8 ppm is cost-effective (upgrades)
 - 2 ppm is not cost-effective
- Incremental assessment
 - No established threshold for I-CE
 - Diminishing emission reductions for considerable cost

FCCU with Existing NOx Controls			
8 ppm		2 ppm	
Cost Effectiveness	Emission Red (tpd)	Cost Effectiveness	Emission Red (tpd)
\$12,000	0.06	\$108,000	0.32

8 → 2 ppm

Incremental Cost-Effectiveness \$127,000

Incremental Em Red (tpd) 0.25

Staff Recommendation:
 Include a near limit of 8 ppm on 365 day and 10 ppm on 7 day rolling average

FCCU – Cost-Effectiveness to Achieve 2 ppm with Outliers Removed

- Staff did not evaluate 8 ppm for the FCCUs without SCR
 - 8 ppm was proposed due to technical feasibility and high cost for retrofitting existing SCRs on FCCUs
- Based on revised cost estimates, 2 ppm is cost-effective for units without NOx controls


FCCU without NOx Controls	
2 ppm	
Cost Effectiveness	Emission Red (tpd)
\$24,000	0.36

Staff Recommendation:
Maintain 2 ppm NOx Limit for FCCU

Staff Comment:
Multiple potential control options to achieve emission reduction objectives were not identified; therefore, incremental cost-effectiveness not presented

Revised BARCT Assessment for FCCU

59



⁽¹⁾ 500 ppm Carbon Monoxide, 3% Oxygen Correction, 365/7-day rolling average

⁽²⁾ Previously estimated emission reductions without near limit: 0.67 tpd

FCCU NOx limit and Oxygen Correction

60

- For the FCCU category, staff proposed that the NOx emission outlet be corrected to zero percent oxygen
- Based on recent permit to construct, permit condition E519.1 requires that NOx emission be corrected to 3 percent oxygen

TABLE 1: NO_x AND CO EMISSION LIMITS

FLUIDIZED CATALYTIC CRACKING UNITS				
	NO _x (ppmv)	CO (ppmv)	Averaging Time (Rolling Average)	Permit Application Submittal Deadline
	0% O ₂			
FCCU	2	500	365 days	July 1, 2022 or pursuant to subdivision (k)
	5	500	7 days	

Staff Recommendation:

Change initial proposal for correcting NOx emissions from 0% to 3% oxygen for consistency with existing permit condition E519.1

Initial Concept for Mass Emissions Approach



BARCT-Compliance Alternative Plan (B-Cap)

62

- In Working Group Meeting #20, discussed recommendations by some industry stakeholders to consider a facility-wide mass emissions approach
 - Discussed challenges and consideration for a facility-based mass approach
- Staff has developed initial concepts for a BARCT equivalent facility-wide mass emissions approach which will be referred to as a BARCT-Compliance Alternative Plan (B-Cap)
- B-Cap is an option that is in addition to:
 - Direct compliance with the NOx limits of Table 1; and
 - The B-Plan which achieves BARCT in aggregate
- Presenting initial concept for B-Cap today – will provide additional details in next Working Group Meeting

Challenges with a Facility-Wide Mass Emissions Based Alternative b-Plan Compliance Options

21

Staff discussing concepts internally

Challenges

- Facility may be forced to reduce production or shutdown if the emissions cap is exceeded leading to an unexpected interruption in fuel supply
- Allowing vastly different compliance approaches could lead to inequities between facilities
- Potentially relieves sources from making any reductions if equipment shutdowns

Considerations for a Mass Based Approach


20

- Alternative compliance options must result in emission reductions equivalent to BARCT, as defined in California Health and Safety Code § 40406:
“an emission limitation that is based on the maximum degree of reduction achievable by each class or category of source, taking into account environmental, energy, and economic impacts.”
- BARCT NOx limits must be technically feasible and cost-effective based on class and category of equipment for all affected facilities
 - Cost-effectiveness is an average, there will be individual units with a cost-effectiveness above the threshold that will have to be retrofitted to meet BARCT
- Must ensure it complies with AB 617
- Requirements for CEMS, SSM, missing data procedure, etc. would have to be similar to RECLAIM

Initial Concepts for B-Cap

63

- **Final Emissions Target** would be based on 2017 activity and proposed NOx limits in Table 1 for each unit
- **Interim Emissions Target** would be based on committed reductions in the i-Plan (~65 to 70% Phase I)
- Each unit must have a concentration limit
- Each unit must meet a minimum level of control (still developing)
- Cannot use RTCs in lieu of meeting interim or final emission targets
- Can use emission reductions from shutdowns to achieve overall mass emission targets
- Staff believes that if new units are added to the facility, there should be provisions to recognize that reductions from shutdowns lessened the obligation to reduce certain units' NOx emissions to Table 1 limits
 - Seeking input on a provision to require that any new unit stays within the Final Mass Emissions Cap (no increase)



Comparison Between Key Elements of Table 1, B-Plan, and B-Cap

Key Elements	Table 1	B-Plan	B-Cap
How is BARCT achieved	Specified NOx Limits from Table 1	In aggregate, based on Table 1	In aggregate, based on Table 1
Can reductions from shutdowns be used to meet BARCT	No	No	Yes
NOx concentration limits for each unit	Yes	Yes	Yes
Use of RTCs to meet emission reductions	No	No	No
Total emission reductions compared to Table 1	N/A	Same as Table 1	Same as Table 1
Throughput limitation	No	No	Yes
Minimum level of control for each unit	Yes	No	Yes
Future limitations for new units at BACT	No	No	Yes
Implementation Schedule	Table 1 or i-Plan	Table 1 or i-Plan	i-Plan

Next Working Group Meeting

65

Scheduled for
July 14, 2021

Staff will present
the BARCT
reassessment for
vapor incinerators
and flares

Continue
discussion of
additional details
of the B-Cap

Continue
discussion on co-
pollutants and
PM2.5 source test

Next Steps

Continue Discussions with Stakeholders



Complete Cost-Effectiveness and BARCT Reassessment



Release Preliminary Draft Staff Report and Rule Language



Public Workshop in August 2021



Public Hearing November 2021

Proposed Rule 1109.1 Staff Contacts

67

Susan Nakamura

Assistant DEO

snakamura@aqmd.gov

909.396.3105

Michael Krause

Planning & Rules Manager

mkrause@aqmd.gov

909.396.2706

Heather Farr

Program Supervisor

hfarr@aqmd.gov

909.396.3672

Sarady Ka

AQ Specialist

ska@aqmd.gov

909.396.2331

Mojtaba Moghani, Ph.D.

AQ Specialist

mmoghani@aqmd.gov

909.396.2527

Zoya Banan, Ph.D.

AQ Specialist

zbanan@aqmd.gov

909.396.2332



RECLAIM Staff Contacts

68

Susan Nakamura
Assistant DEO

snakamura@aqmd.gov
909.396.3105

Michael Morris
Planning & Rules Manager

mmorris@aqmd.gov
909.396.3282

Uyen-Uyen Vo
Program Supervisor

uvo@aqmd.gov
909.396.2238

Lizabeth Gomez
AQ Specialist

lgomez@aqmd.gov
909.396.3103

Isabelle Shine
AQ Specialist

ishine@aqmd.gov
909.396.3064



Rule 429 Staff Contacts

69

Susan Nakamura

Assistant DEO

snakamura@aqmd.gov

909.396.3105

Michael Morris

Planning & Rules Manager

mmorris@aqmd.gov

909.396.3282

Rudy Chacon

Acting Program Supervisor

rchacon@aqmd.gov

909.396.2206

Isabelle Shine

AQ Specialist

ishine@aqmd.gov

909.396.3064

